

Cabin Meeting  
July 3, 2014  
9:00 to 10:15 a.m.

Present:

Carl Goodman and Ed Kerr – Kimble Lake Cabin Committee  
John Pinka – Hopkinton Building Inspector  
Thatcher Plante – Fire Inspector

The meeting was held to discuss safety issues and ADA compliance of cabins located at the Kimble Lake Recreational area.

Items Discussed:

1. Handicapped accessibility – It was decided that a new rear door will be added on cabin I (double cabin). All doors will be widened to 36 inches and will open out, as other cabins are removed. Doors will be widened and porches made handicapped assessable by ramps.
2. All exit doors to have lit exit signs and emergency battery combination units. Smoke detectors will be hardwired in each cabin with two in the large cabin.
3. Porch railings will be modified for safety, but still retain the character of the original cabins.
4. Fireplace in cabin was discussed. It was decided, if deemed safe by a mason, that limited use by authorized personnel would be allowed.

Respectfully submitted,

Carl Goodman